


GOOSENECK Z821T0-XL-WM TAG

Engineering Specifications: Zurn AquaSpec[®] Z821T0-XL-WM

Polished chrome-plated, brass rigid 4-1/2" [114mm] centerline rigid wall-mounted gooseneck spout with vacuum breaker. Unit is furnished with a 2.2 GPM [8.3 L] pressure compensating aerator (complying with ANSI A112.18.1 Standard for flow).

Zurn Lead Compliant* "XL" products are a line of durable, high quality brass faucets and fixtures that are designed and manufactured to comply with state laws and local codes that mandate lead content levels. Zurn "XL" products are manufactured with *not more than 0.25% lead content when used with respect to wetted surfaces of pipes and pipe fittings, plumbing fitting and fixtures: California Health & Safety Code § 116875; Vermont 9 VCA § 2470h.



Note: All dimensions are for reference only. Do not use for pre-plumbing

OPTIONAL ACCESSORIES

Suffix	Description
LP	Low Profile
PT	1-1/4" [32mm] Cast Brass P-Trap with a 7-1/2" [191mm] Long 17-Gauge Wall Bend
-2M	2.2 GPM [8.3 L] Vandal-Resistant Pressure Compensating Male Aerator
-3M	0.5 GPM [1.9 L] Vandal-Resistant Pressure Compensating Male Spray Outlet
4M	2.2 GPM [8.3 L] Vandal-Resistant Pressure Compensating Male Laminar Flow Outlet
7M	1.0 GPM [3.8 L] Pressure Compensating Male Spray Outlet
16M	1.0 GPM [3.8 L] Vandal-Resistant Pressure Compensating Male Spray Outlet
17M	1.5 GPM [5.7 L] Vandal-Resistant Pressure Compensating Male Aerator
	1.5 GPM [5.7 L] Vandal-Resistant Pressure Compensating Male Laminar Flow
19M	1.5 GPM [5.7 L] Anti-Microbial Pressure Compensating Male Laminar Flow Outlet
21M	1.0 GPM [3.8L] Male Laminar Flow Outlet
22M	1.0 GPM [3.8L] Vandal-Resistant Male Laminar Flow Outlet
-23M	1.5 GPM [5.7L] Pressure Compensating Male Aerator

ZURN INDUSTRIES, LLC ♦ COMMERCIAL BRASS OPERATION ♦ 2640 SOUTH WORK STREET ♦ FALCONER NY 14733 Phone: 1-800-997-3876 ♦ Fax: 1-919-775-3541 ♦ www.zurn.com In Canada: ZURN INDUSTRIES LIMITED ♦ 3544 Nashua Drive ♦ Mississauga, Ontario L4V1L2 ♦ Phone: 905/405-8272 Fax: 905/405-1292