## PROCEPTOR FRAME/COVER **BONDED TO TANK** INSTALL FLOW **VENT** CONTROL AT INLET; **USE ADAPTORS** WHERE REQUIRED **CLEANOUT** INLET OUTLET CONCRETE FLOOR

## MUST BE INSTALLED WITH SUPPLIED FLOW CONTROL DEVICE AS TESTED AND AS SHOWN IN DRAWING

## NOTES:

- ENSURE FLOOR IS LEVEL, SMOOTH AND IS ABLE TO SUPPORT THE WEIGHT OF THE TANKS FULL OF WATER AT THE INSTALLATION LOCATION. TANK BOTTOM IS TO BE FULLY SUPPORTED.
- MOVE TANKS INTO POSITION. CHECK FIT AND LOCATION OF INLET, OULET AND VENT PIPING.
- IF APPLICABLE, CONNECT OUTLET OF UPSTREAM TANK WITH INLET OF DOWNSTREAM TANK
- 4. ENSURE ACCESSWAY IS ACCESSIBLE FOR COVER REMOVAL AND PUMPOUT AS WELL AS ACCESS TO THE INTERIOR. ENSURE ALL OTHER PORTS ARE ACCESSIBLE FOR INSTALLATION AND MAINTENANCE. ALARM OR LEVEL PROBE (IF SUPPLIED) SHOULD HAVE SUFFICIENT HEADSPACE FOR REMOVAL FOR SERVICE.
- 5. ENSURE AREA AROUND TANK IS HEATED TO PREVENT FREEZING OF WATER IN TANKS AND PIPES.
- THE STABILIZATION BRACKETS (IF EQUIPPED) MAY BE AFFIXED TO FLOOR IF DESIRED.
- SEISMIC RESTRAINTS TO BE PROVIDED BY OTHERS IF REQUIRED BY LOCAL AUTHORITIES
- 8. INSTALL INLET, OUTLET AND VENT PIPES TO MEET LOCAL PLUMBING CODE.
- UNITS MUST BE INSTALLED IN ACCORDANCE WITH ALL RELEVENT FEDERAL, STATE/PROVINCIAL AND LOCAL CODES

GMC MODEL SIZE (CAPACITY US GAL)	INLET (A)	OUTLET (B)	WEIGHT OF TANKS FULL OF WATER (LBS)	WEIGHT OF EMPTY TANKS (LBS)
50 CSA	12	11	611	130
100 CSA/PDI	20	19	1040	150
150 IAP	33	32	1473	175
200 CSA/PDI	36	35	1912	205
250 CSA/PDI	44	43	2346	230
300 CSA/PDI	52	51	2779	255

DWG. TITLE: INSTALL GMC 50-300 S24M PDI AND CSA FC24FB

PROJECT:

**Proceptor**\*



SIZE

DRAWING NOT TO SCALE

DWG #: 19-5239-\$

REV. 1