
PROCEPTOR GMC / OMC SINGLE TANK ELLIPSE MODELS **ABOVE GROUND** INSTALLATION PROCEDURE

NOTES:

- 1. ENSURE FLOOR IS LEVEL, SMOOTH, AND IS ABLE TO SUPPORT THE WEIGHT OF THE TANK FULL OF WATER AT INSTALLATION LOCATION.
- 2. MOVE TANK INTO POSITION. CHECK FIT AND LOCATION OF INLET, OUTLET AND VENT PIPING WHERE APPLICABLE.
- 3. ENSURE MANWAY IS ACCESSIBLE FOR COVER REMOVAL AND PUMPOUT AS WELL AS ACCESS TO THE INTERIOR. ENSURE ALL OTHER PORTS ARE ACCESSIBLE FOR INSTALLATION AND MAINTENANCE. ALARM PROBES SHOULD HAVE SUFFICIENT HEADSPACE FOR REMOVAL TO CALIBRATE OR SERVICE.
- 4. ENSURE AREA AROUND TANK IS HEATED TO PREVENT FREEZING OF WATER IN TANK AND PIPES.
- THE STABILIZING SUPPORTS MAY BE AFFIXED TO FLOOR IF DESIRED.
- 6. SEISMIC RESTRAINTS TO BE PROVIDED BY OTHERS IF REQUIRED BY LOCAL AUTHORITIES
- 7. INSTALL INLET, OUTLET AND VENT PIPES (IF REQUIRED).
- 8. PRIOR TO COMMENCING OPERATIONS, FILL TANK WITH CLEAN WATER.
- 9. US PATENT # 5,746,912; CDN PATENT # 2,195,822



| PROCEPTOR SEPARATOR MODEL | INLET INVERT TO TANK BOTTOM (H) | WEIGHT OF TANK FULL OF WATER |
|---------------------------------|---------------------------------------|---------------------------------|
| MC 50 | 12" | 550 |
| MC 100 | 20" | 985 |
| MC 150 | 28" | 1445 |
| MC 200 | 36" | 1890 |
| MC 250 | 44" | 2335 |
| MC 300 | 52" | 2780 |
| MC 500 | 32" | 4690 |
| MC 750-LEA* | 45" | 6885 |
| MC 1000(1)-LEA* | 59" | 9050 |
| MC 1300-LEA* | 74" | 11650 |
| MC 1500(1)-LEA* | 85" | 13380 |
| | | |

* WITH STABILIZERS TO PREVENT TIPPING

(PROCEPTOR SEPARATORS MUST BE INSTALLED IN ACCORDANCE WITH ALL RELEVANT FEDERAL, PROVINCIAL/STATE, AND LOCAL CODES INCLUDING LOCAL PLUMBING CODE)

* ACTUAL HEIGHT MAY VARY.

| TITLE: PROCEPTOR SEPARATOR | REV | DATE | DRAWN | |
|----------------------------|------|-------------------|------------|------------------------------------|
| INSTALLATION PROCEDURE | 1 | MARCH 13, 2006 | L. SIMKINS | Dracantar |
| FOR ABOVE GROUND MC MODELS | 2 | MARCH 16, 2006 | L. SIMKINS | Pro ceptor® |
| TON ABOVE GROOND WO WODELS | 3 | JULY 11, 2006 | L. SIMKINS | <i>I</i> |
| ALL DIMENSIONS IN INCHES | 4 | OCT0BER 24, 2006 | L. SIMKINS | R |
| PROJECT: WO: | 5 | DEC. 8, 2006 | L. SIMKINS | by greenturtle [®] |
| PROJECT. WO. | 6 | AUGUST 13, 2009 | L. SIMKINS | by greentance |
| | 7 | JAN 21, 2011 | L. SIMKINS | US 877 428 8187 CAN 877 966 9444 |
| ✓ OPTIONS: | 8 | NOVEMBER 21, 2011 | L. SIMKINS | |
| ALARM | 0 | JAN. 08, 2013 | S. MANGAT | www.greenturtletech.com |
| SUCTION | 7 | | | SIZE DWG NO REV. |
| | -110 | | | SIZE DWG. NO. REV. |

DRAWN BY: L. SIMKINS

DRAWN DATE 11/23/5

DOUBLE WALL

A | INSTALL MC ABOVE GROUND

9

SCALE:1:35 DO NOT SCALE DRAWING SHEET 1 OF 1